



1 Third Floor Plan - Electrical Power Demolition
1/8" = 1'-0"

ELECTRICAL DEMOLITION NOTES

1. WHERE COMPLETE CIRCUITS ARE DEMOLISHED, THE WIRING AND RACEWAY SHALL BE DEMOLISHED BACK TO THE BRANCH CIRCUIT PANELBOARD. THE DEMOLISHED CIRCUIT'S BREAKER SHALL BE LABELED AS "SPARE" ON THE PANEL SCHEDULE.
2. WIRING AND RACEWAY SHALL BE PROVIDED AS NECESSARY TO RE-ENERGIZE EXISTING OUTLETS TO REMAIN WHEN POWER TO SUCH OUTLETS IS INTERRUPTED DUE TO DEMOLITION OF OTHER DEVICES ON THE SAME CIRCUIT.
3. CONTRACTOR SHALL USE CARE IN REMOVING DEVICES AND FIXTURES AND SHALL MAKE THEM AVAILABLE TO THE OWNER FOR FUTURE USE. ALL DEVICES AND FIXTURES NOT RETAINED BY THE OWNER SHALL BE DISPOSED OF BY THE CONTRACTOR IN ACCORDANCE WITH THE OWNER'S INSTRUCTIONS.
4. ALL PENETRATIONS OF FIRE RATED PARTITIONS DUE TO THE REMOVAL OF ELECTRICAL SYSTEMS SHALL BE SEALED TO MAINTAIN THE FIRE RATING OF THE WALL.
5. ALL EXISTING DEVICES AND EQUIPMENT MAY NOT BE SHOWN ON PLANS. CONTRACTOR SHALL VISIT THE SITE BEFORE SUBMITTING BID TO OBSERVE EXISTING CONDITIONS.
6. ALL FIRE ALARM SYSTEM DEVICES REMOVED FROM AREAS TO BE RENOVATED SHALL BE SALVAGED FOR RE-USE. REMOVE, STORE, AND CLEAN BEFORE RE-INSTALLINGS. REFER TO DRAWING ES-07 FOR NEW LOCATIONS.
7. MOST DEVICES SHOWN IN EXISTING PATIENT ROOMS HAVE BEEN REMOVED. BOX AND BLANK COVERPLATE REMAIN.


KEYED NOTES

1	PNEUMATIC TUBE STATION TO REMAIN
2	DEVICES AND EQUIPMENT TO REMAIN IN EXISTING ELECTRICAL ROOM AND I.T. CLOSET. REMOVE ALL CONDUIT, J-BOXES, AND WIRING BACK TO THIS ROOM.

Revision	Date

CONSULTANTS:

Smith Seckman Reid, Inc.
11460 Tomahawk Creek Pkwy Suite 320
Leawood, Kansas 66211
p. (913) 319-3562
f. (913) 319-3579
www.ssr-inc.com



ARCHITECT:

**Ta TOMPKINS
architects**

507 Walnut Street, Suite 200, Kansas City, MO 64106
p. 816 472 5656 f. 816 472 5657 www.tom-arch.com

COPYRIGHT 2011 BY TOMPKINS
ARCHITECTS, INC. ALL RIGHTS
RESERVED. NO PART OF
THESE DOCUMENTS MAY BE
REPRODUCED, STORED IN A
RETRIEVAL SYSTEM, OR
TRANSMITTED IN ANY FORM OR
BY ANY MEANS, ELECTRONIC,
MECHANICAL, PHOTOCOPYING,
RECORDING, OR OTHERWISE,
WITHOUT THE PRIOR WRITTEN
PERMISSION OF TOMPKINS
ARCHITECTS, INC.

Drawing Title
**Electrical Demolition Plan
- Power**

Approved:

Project Title RENOVATE 3K FOR MENTAL HEALTH O/P CLINICS
Location G.V. (SONNY) MONTGOMERY VA MEDICAL CENTER
Date 03/09/12

Project Number 586-09-114
Building Number 3K
Drawing Number ES-03

G.V. (SONNY) MONTGOMERY VA MEDICAL CENTER 1500 E WOODROW WILSON JACKSON, MS 39216
Department of Veterans Affairs